

		<p>MUKWONAGO FIRE DEPARTMENT</p> <p>OPERATING PROCEDURES</p>	
Standpipes		Approved by: Chief Jeffrey A. Rolfe	
SOG #22	Draft Date: 10-13-09	Revision Date:	Effective Date:

PURPOSE: To establish procedures for the use of Fire Department standpipes.

SCOPE: This procedure is to be followed by all officers and members of this department. Authority to deviate from this procedure rests with the officer in charge of the incident who will be responsible for the results of any deviation.

- A. It shall be the normal operation of the Mukwonago Fire Department to attach to any existing standpipes installed on structures to which we are responding for a possible or confirmed fire. Attachment will be made with the appropriate size supply hose once a suitable water supply source has been established.
- B. Working pump pressure when supplying a building standpipe will be a minimum of 150 p.s.i. unless otherwise directed by the incident commander.

Chief of Department